



CONSULTING ENGINEERS GROUP LTD

An ISO 9001:2008 Company
Plot No. 61 A/B, Balaji Nagar, Behind Suman Motel
At Post: Morane Taluka, Dist.: Dhule-424001 (Maharashtra)

CEG/Proj/Fagne to Mah-Guj Br/2017/658

01ST May, 2017

To

Mr. M. Kamalpathy,

Project Director,
FagneSongad Expressway Limited,
S.No.62/2, Plot No.5, Shiv Sagar Park,
Sakri Road, Dhule – 424001
Maharashtra

(Email: M.Kamalpathy@ilfsindia.com; & fselitnl@gmail.com; & Sanjay.Jijja@ilfsindia.com;))

Sub: Independent Engineer Services for 4-lanning of **Fagne to Mah-Guj. Border** (Package-3) Section of NH-6 in the State of Maharashtra from Km 510.000 to Km 650.794 to be executed as BOT (Toll) basis on DBFOT pattern under NHDP Phase-IV – **Submission for approval of concrete mix design M-25 with Dahyane Quarry & Supreme admixture – Reg.**

Ref: FSEL/PRJ/TEC/ICO-581/498 dated 13.04.2017

Dear Sir,

The submitted test results for above mentioned captioned grade of mix design were reviewed which meet to the requirement of specification are being returned as duty concurred with following terms and condition.

1. In case any change of ingredient used in mix design the Concessionaire will have to produce separate mix design for above mentioned grade of concrete.
2. If the performance of above cited mix design seems to be poor in accordance with compressive strength and workability, the concurrence of above cited mix design will be automatically revoked.
3. The workability test must be followed to fulfill the requirement of IS:1199 and IS: 456as on site.
4. The compressive strength must be conducted as per the requirement of MoRT&H CI:1716.2.4
5. In case any change for source of material, the Concessionaire will have to produce separate mix design for above mentioned grade of concrete.

This is for information and further immediate action please

Thanking You.

Sincerely Your's,

(Handwritten signature)
11/5/17

(Vishram.D.Patil)

Team Leader Cum Sr. Highway Engineer
Fagne to Mah-Guj. Border(Package-3)
Section of NH-6,Dhule.

Copy to:

1. The Project Director, NHAI, PIU, Dhule,S.No.10/2,Plot No.11, Mansaram Nagar,Near Circuit House, Sakri road,Dhule - 424 002, Maharashtrafor information and necessary action please.
(Email: dhule@nhai.org; & piudhule@gmail.com;)
2. Col. Sanjay Bajpai (Retd), Vice President (Co-ordination), CEG, CEG Tower, B-11 (G) Malviya Industrial Area, Jaipur – 302017 for information please.
(Email: bajpaisanjay@cegindia.com;)
3. Office file.