



LEA Associates South Asia Pvt. Ltd.

H. No. A11, Batra Colony (South City)

Bharatpur, P.O. Kaushalgang, Tehsil

Bilaspur, Dist. Rampur, Uttar Pradesh- 244923, India

E-mail: lasarudrapur@lasaindia.com, www.lasaindia.com

Corporate Identification Number: U74899DL1993PTC055750

Date: 04.08.2018

LASA/NH-87/ P-2/SNHPL/2018/0149

To

Authorized Representative
Sadbhav Nainital Highway Private Ltd.
Opp. Reliance Petrol Pump, NH- 87
Village- Padalipur, Post – Motahaldu
Tah.- Lalkuan, Dist. - Nainital-263139 UKD.

Sub:- Four laning of Rampur- Kathgodam section of NH-87 (New NH Nos.,9,109)from KM 42.791(Design Chainage 43.446) to KM 88.000 (Design Chainage 93.226)[Package-II] in the state of Uttarakhand under NHDP Phase-III on Hybrid Annuity Mode- **Source Approval for Curing Compound -Reg.**

Ref:- 1. SNHPL/R-K PKG-II/PO/FY2018-19/LASA/00285, dated: 19.07.2018

Sir,

With reference to the captioned works and subject matter we reviewed your submissions in connection with curing compound as per MORT&H clause no. 601.6.1,1712.4 and IS: 7542 & ASTM C-309 for following the manufactures and found in order.

1. Bharatbuild Conchem Solutions. Ghaziabad (UP)
2. Molcules Conchem Pvt. Ltd. Jind (HR)
3. Supreme Bituchem. Nagpur (MH)

The acceptance of the curing compound will be subject to following :-

- (i) Supply of each lot conforms to requirement of IS: 7542 & ASTM C-309.
- (ii) Every lot/consignment should accompany the manufacture's test certificate.
- (iii) The first consignment and subsequently at reasonable regular intervals, the consignments may have to be got tested for physical and chemical properties through third party, NABL approved testing laboratory or any prime engineering institute or reputed.
- (iv) If any test specimen selected from the lot fails, no retesting shall be done and the entire lot is liable to be rejected.
- (v) If any material is found to be defective at any stage, the same shall have to be removed immediately from the site.
- (vi) Strict compliance of stipulations as mentioned in clause 8.1 of IRC: SP: 84-2014 is required to be ensured.
- (vii) The right to reject the above source without any prior notice is hereby reserved if it is found that the product has failed to comply the specifications of above conditions.
- (viii) The above review by the Independent Engineer shall not absolve the Concessionaire of its responsibilities as envisaged in the Concession Agreement.

Thanking You

Yours truly

For LEA Associates South Asia Pvt. Ltd.

(Arun Kumar)

Team Leader

CC: - 1. The Project Director, NHAI, PIU Rudrapur. – for his kind information.