



# Marc Technocrats Private Limited

CIN : U74210DL2007PTC166575

Corp. Office : Marc House, Sector 6-7 Dividing Road, Opp. Devi Lal Park, Bahadurgarh, Haryana-124507  
E-mail : [mct\\_rtk@rediffmail.com](mailto:mct_rtk@rediffmail.com), Ph.: 01276-645290, Telefax : 01276-242015

Ref No: :MARC-DSD/TL/PKG III/AI/2018-19/255

Dated:18.04.2018.

To,

Project Manager  
Ajwani Infrastructure Pvt.Ltd.  
Nagbhir-Armori NH-353D Project  
Nagbhir (Nagpur)

Sub:- Consultancy Services of Authority's Engineer Services for Supervision of Two-laning with paved Shoulder from km 97/487 to km 137/250 of NAGPUR-UMRED-NAGBHIR-ARMORI NH-353D section Nagbhi to Armori in the state of Maharashtra on EPC Mode.

**Reg:- Permission for use of Sealant as per the test report**

**Ref:** 1) Contractor letter no.AIPL/NW/SKB/NBD/294/03 of 2018 Dated - 23-03-2018

Dear Sir,

This is in response to your letter cited under reference over mentioned subject and your submission under reference vide which you had submitted test report of "SEALANT" SUPER SEAL -PS of Supreme Bituchem India Pvt.Ltd.The test reports seems tenable as per the IS:12118,IRC-57 & ASTM C 920 and found in confirmation to clause 602.10.3 of MORTH.

Consequently, the permission to use the "SEALANT" of aforementioned brand is accorded for the PQC/Structure works as per provisions of contract & this approval would be subjected to persistency & consistency of the quality of the SEALANT in future. Contractor is advised to proceed further with due intimation to the office of undersigned, giving due diligence to safety and environment protection, with out compromising quality & durability while carrying out the work.

Thanks & Regards

Your's faithfully

Marc Technocrats Pvt.Ltd

K.Sambasiva Rao

Team Leader cum Sr.Bridge Engineer

Nagbhir-Armori NH- 353D Project

Brahmapuri

Copy to-Superintending Engineer, NH, Nagpur-For Information Pls.

Executive Engineer, NH, Nagpur-For Information Pls.

SDO, NH, Nagpur-For Information Pls.

Marc Technocrats Pvt.Ltd, Bahadurgarh-For Information Pls.